

Life Safety Inspection Checklist

Address

- Address is posted on outside of business and viewable from the public way (min. 4 letters).
- Tenant identification/address of business is on rear door of multi-tenant buildings (strip malls).

Construction Features

- Ceiling tiles in place.
- No holes in walls for fire resistive construction.

Electrical Equipment

- No extension cords are being used as permanent wiring.
- No multiplying adapters are being used (power strips are acceptable) must be mounted off floor.
- Electrical panel boxes, receptacles, and light switches have proper covers on and/or are closed.
- No storage items blocking access to electrical panel box and water heaters (36" clearance).

Exits and Egress

- Emergency lighting is operable.
- Exit signs illuminated (on battery back-up if applicable).
- All exits and exit aisles are clear of obstructions.

Fire Alarm System

- Pull stations are not obstructed from view.
- Fire alarm system is operable and annual testing is current (proof of certification on site).

Fire Extinguishers and Kitchen Extinguishing Systems

- Extinguisher is properly mounted on wall and is not obstructed from the public.
- Extinguisher has a current annual recertification tag or bi-annual for Ansul systems.
- Kitchen hood exhaust is free of grease and clean.
- Hood exhaust extinguishing system recertification is current.

Housekeeping

- Combustibles are not stored near heating source (furnace, water heater, etc.).
- Housekeeping is orderly inside and outside of building.
- No storage within 18" (vertically) of sprinkler heads.
- Compressed gas cylinders must be secured to wall, rack, or cart.

Fire Sprinkler System

- Fire department connection cap(s) are in place.
- Fire department connection is accessible (36" clearance of shrubbery, etc.).
- Sprinkler system is operable and annual testing is current (proof of certification on site).
- 20' clear driveway around building.

*This is not an all-inclusive list. This is to help you in your Annual or new business License Life Safety inspection. Any questions, please contact the **Lumpkin County Fire Marshal's office at (706)-462-2660.**